

**2.1.15 Aggregate Residential Building Component Loads as of 1998 (1)**

Component	Load (quads) and Percent of Total Load			
	Heating		Cooling	
Roof	-0.65	12%	0.16	14%
Walls	-1.00	19%	0.11	10%
Foundation	-0.76	15%	-0.07	-
Infiltration	-1.47	28%	0.19	16%
Windows (conduction)	-1.34	26%	0.01	1%
Windows (solar gain)	0.43	-	0.37	32%
Internal Gains	0.79	-	0.31	27%
<b>Net Load</b>	<b>-3.99</b>	<b>100%</b>	<b>1.08</b>	<b>100%</b>

Note(s): 1) "Load" represents the thermal energy losses/gains that when combined will be offset by a building's heating/cooling system to maintain a set interior temperature (which equals site energy).

Source(s): LBNL, Residential Heating and Cooling Loads Component Analysis, Nov. 1999, Figure P-1 and Appendix C: Component Loads Data Tables.